

CERTIFICATE OF CONSTANCY OF PERFORMANCE

0751-CPR-223.1-01

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Mineral wool products

Thermal insulation products for buildings

Factory made mineral wool (MW) products acc. EN 13162:2012+A1:2015

(details see annex)
produced by or for

Saint-Gobain Construction Products Romania SRL
Floreasca Park, Sos. Pipera nr. 43, corp A, etaj 3, Sect. 2
BUCHAREST
ROMANIA

and produced in the manufacturing plant(s)

EU

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standards(s)


EN 13162:2012+A1:2015

under **System 1** are applied and that

the products fulfil all the prescribed requirements set out above.

This certificate was first issued on 21.10.2015 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly (but not longer than 19.08.2019).

Gräfelfing, 20.08.2018



Dipl.-Ing. (FH) Wolfgang Albrecht

Head of Certification Body

ANNEX TO CERTIFICATE OF CONSTANCY OF PERFORMANCE

No.: 0751-CPR-223.1-01

Factory: Terpni Serres, Greece

Construction product(s): Factory made mineral wool (MW) products acc. EN 13162:2012+A1:2015

Intended use: Thermal insulation products for buildings

**Level(s) or class(es)
Reaction to fire:** For uses subject to regulations of reaction to fire A1, A2, B, C.
Products for which a clearly identifiable stage in the production process results in an improvement in the reaction to fire classification.

Attestation of conformity system: 1

Table 1: Description of the building products

Note: All products without facings have fire classification A1

No.	Product		Thickness Range [mm]	Classification			
	Name	Description		Reaction to fire class	Facing	Loss of Ignition [mass %]	Thickness Range [mm]
1	ISOVER PROFI FASSADE	board	30 - 300	A1	AL ¹ , YM ² , YA ³	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
2	ISOVER PROFI TERRASSE R	board	30 - 300	A1	AL ¹	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
3	ISOVER PROFI TERRASSE Ti	board	30 - 300	A1	AL ¹	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
4	ISOVER PROFI TERRASSE T	board	30 - 300	A1	AL ¹	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
5	ISOVER PROFI TERRASSE Si	board	30 - 60	A1	AL ¹	≤ 5,7	≥ 20
			70 - 100	C-s1, d0	AX ⁴		
6	ISOVER PROFI TERRASSE Si	board		110 - 200	A1	AL ¹	≤ 5,7
			C-s1, d0		AX ⁴		
7	ISOVER PROFI TERRASSE S	board	30 - 300	A1	AL ¹	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
8	ISOVER FASSADE	board	40 - 300	A1	-	≤ 5,7	≥ 20
				C-s1, d0	AX ⁴		
9	ISOVER FASSADE	board	40 - 300	A1	-	≤ 5,7	≥ 20

¹ AL - Aluminium compound foil

Classification report: MPA BAU Hannover no. 153214

² YM - Black glass tissue

Classification report: MPA BAU Hannover no. 153139

Note: All products without facings have fire classification A1

³ YA - White glass tissue

Classification report: MPA BAU Hannover no. 152467

⁴ AX - Reinforced aluminum craft foil

Classification report: MPA BAU Hannover no. 153219

Gräfelfing, 14.09.2018



Dipl.-Ing. (FH) Wolfgang Albrecht



1508 Head of Certification Body